



# Case Study on Power Generation from Agrivoltaic System in India

**U. R. Patel <sup>a\*</sup>, G. A. Gadhiya <sup>a</sup> and P. M. Chauhan <sup>a</sup>**

<sup>a</sup> *Department of Renewable Energy Engineering, College of Agricultural Engineering and Technology, Junagadh Agricultural University, Junagadh-362001, Gujarat, India.*

## **Authors' contributions**

*This work was carried out in collaboration among all authors. All authors read and approved the final manuscript.*

## **Article Information**

DOI: 10.9734/IJECC/2023/v13i92375

## **Open Peer Review History:**

This journal follows the Advanced Open Peer Review policy. Identity of the Reviewers, Editor(s) and additional Reviewers, peer review comments, different versions of the manuscript, comments of the editors, etc are available here: <https://www.sdiarticle5.com/review-history/103345>

**Original Research Article**

**Received: 21/05/2023**

**Accepted: 13/07/2023**

**Published: 19/07/2023**

## **ABSTRACT**

This study evaluates the performance of a 7.2 kWp SPV power plant that was installed in the field of the REE department of the College of Agriculture Engineering and Technology, JAU, Junagadh (21.5 N, 70.1 E). According to the International Energy Agency (IEA), the SPV power plant's performance was evaluated. The power plant was properly observed for whole year. Average system efficiency, capacity factor, and overall performance ratio were found to be 80.83%, 16.03%, and 12.07% respectively during the experiment. Total 10104.77 kWh were produced during the experimental period. The performance of this Agrivoltaic system is produce equivalent solar power as it is from PV systems installed.

*Keywords: Agrivoltaic; power plant; final & reference yield; efficiency.*

## **1. INTRODUCTION**

It is anticipated that the world's population is currently 7.7 billion and will be increase to 8.5

billion in 2030 or 9.7 billion in 2050 as a result of recent population increases [1]. As a result, the necessities of the global society are expanding [2]. Due to this and the damaging effects that

\*Corresponding author: E-mail: [patelurvashi4@gmail.com](mailto:patelurvashi4@gmail.com);

conventional or energy based on fossil fuels has on the environment, institutions are supporting the transition to a sustainable energy paradigm. In order to address this tremendous issue, renewable energy sources are becoming more and more important.

Numerous advantages include universal accessibility, simplicity of installation, low maintenance and acquisition costs, improved efficiency, and durability for renewable energy sources. A decrease in the LCOE (Levelized Cost of Energy) is another benefit of these characteristics sources [3,4]. As a result, the amount of PV electricity installed globally has sharply increased. The strong growth of renewables means their share of the global power generation is forecast to rise from 29% in 2022 to 35% in 2025 [5]. PV energy has its critics since historically speaking, the vast areas of land set aside for grid-connected PV facilities are no longer appropriate for agri-food production. The likelihood of satisfying the rising food demand brought on by population increase is negatively impacted by this reality [6], especially in locations with limited land resources and dense populations [7].

Agrivoltaic system, the solution to this issue is to combine PV with agricultural output on the same piece of land. PV panels are set up in this manner so that farming is viable beneath them. Goetzberger and Zastrow first put forth this idea in 1982 [8]. However, it took three decades before it was deployed in test Agrivoltaic plants [7]. Since then, a number of studies have assessed the behaviour of Agrivoltaic system

from an agricultural and energy perspective [9-13]. Regardless of the fact there's not many industrial or research facilities [7]. PV panels have an impact on crop productivity since they lower incident irradiance levels and partially shade the crop [14-16].

## 1.1 Objective

In this work, the 7.2 kW SPV power plant performance is carried out with the following goals in mind.

- 1) To assess the SPV power plant's energy generation performance in accordance with the International Energy Agency (IEA).

## 2. DESCRIPTION OF THE AGRIVOLTAIC SYSTEM

For this study, the experimental SPV Power Plant construction that was previously designed and established at the Department of Renewable Energy Engineering has been considered for assessment. The SPV power plant's overall rating was 7.2 kW, or 0.047 kW/m<sup>2</sup>, spread across an area of 153.88 m<sup>2</sup>. The SPV power plant was constructed so that the amount of shade that affects crops is minimised and that land utilisation is comparable to the traditional SPV power plant design, meaning that the quantity of energy produced per unit land area is unchanged. To ensure that the SPV panels get the majority of solar radiation, the tilt angle of the SPV panels is fixed at 21.5 N, which is equal to the latitude of the Junagadh region.





Fig. 1. Isometric view of SPV power plant



**Fig. 2. Schematic diagram of SPV power plant output**

With 12 numbers of solar panels in each row, each with a 150 W output capacity, there were a total of 48 polycrystalline solar panels fixed in four rows in the shape of a chessboard and installed facing south. Open circuit voltage (VOC) and short circuit current (ISC) ratings for polycrystalline panels are 22.30 V and 8.82 A, respectively. Its operating cell temperature is 48°C plus 2°C. 1.34 metres separate the panels (from panel to panel). According to Fig. 1, the bottom end of the panels was 3.50 m above the ground. Panels are cleaned twice a month to increase yield. To convert DC electricity into AC power, an inverter with a fixed power rating of 7.5 kVA was used. Fig. 2 depicts the SPV power plant's output path.

- Performance ratio (PR)
- Capacity factor (CF)
- System efficiency ( $\eta_{sys}$ )
- The specifications of solar panels are listed in the Table 1.

**Table 1. Specification of the solar photovoltaic module**

PV module	Specifications
Type of material	Poly crystalline
Maximum power $P_{max}(W)$	150
Open circuited voltage $V_{oc}(V)$	22.3
Short circuited current $I_{sc}$ (A)	8.82
Maximum power voltage $V_{max}$ (V)	18.3
Maximum power current ( $I_{max}$ ) (A)	8.2
No. of cells in a module	(4 × 9) 36 nos.
Module dimensions (mm)	70 × 35

### 3. METHODOLOGY

#### 3.1 Performance Analysis of the Agrivoltaic System

The specifications of solar panels are listed in the Table 1. For the performance analysis of the SPV power plant, the following six metrics for performance were taken into account as shown in Table 2. These performance indicators essentially show how well the system performs overall in terms of energy output, solar resource utilisation, and overall system losses.

- Total energy generated by the PV system ( $E_{AC}$ )
- Final yield ( $Y_F$ )
- Reference yield ( $Y_R$ )


### 4. RESULTS AND DISCUSSION

#### 4.1 Monthly Total Energy Generated from Agrivoltaic System

Solar modules transform the solar radiation they collect into usable power. The total amount of energy produced was expressed in kWh. Fig. 3 displays the calculated monthly energy output for the experimental period. 10104.77 kWh in total were produced during the experimental period.

**Table 2. Performance parameter of Agrivoltaic Power Plant**

Total energy generated by the PV system ( $E_{AC}$ )	$E_{(AC,d)} = \sum_{t=1}^{24} E_{(AC,t)}$ , $E_{(AC,m)} = \sum_{d=1}^n E_{(AC,d)}$	$E_{(AC,t)}$ = Total hourly AC energy output (kW h), $E_{(AC,d)}$ = Total daily AC energy output (kW h), $E_{(AC,m)}$ = Total monthly AC energy output (kW h).
Final yield ( $Y_F$ )	$Y_F = \frac{E_{AC}}{P_{PV,Rated}}$	$Y_F$ = Final yield (kW h/kWp) $E_{AC}$ = AC energy output (kWh), $P_{PV,Rated}$ = Rated output power (kWp).
Reference yield ( $Y_R$ )	$Y_R = \frac{H_t(kWh/m^2)}{G(kW/m^2)}$	$Y_R$ = Reference yield (kW h/kWp), $H_t$ = Total in-plane solar insolation (kW h/m <sup>2</sup> ), $G$ = Reference irradiance (kW/m <sup>2</sup> ).
Performance ratio (PR)	$PR (\%) = \frac{Y_F}{Y_R} \times 100$	$Y_F$ = final yield (kW h/kWp), $Y_R$ = Reference yield (kW h/kWp).
Capacity factor (CF)	$CF = \frac{E_{AC,a}}{P_{PV,a} \times 8760} \times 100$	CF = Capacity factor (%) $E_{(AC,a)}$ = Total annual AC energy output (kW h), $P_{PV,a}$ = Total amount of energy generated (kW h)
System efficiency ( $\eta_{sys}$ )	$\eta_{sys,m} = \frac{E_{AC,m}}{H_t \times A_m} \times 100$	$\eta_{sys,m}$ = Monthly system efficiency (%), $E_{(AC,m)}$ = Total monthly AC energy output (kW h), $H_t$ = Total in-plane solar insolation (kW h/m <sup>2</sup> ), $A_m$ = Total area (m <sup>2</sup> ).



**Fig. 3. Monthly energy generation for different months from SPV power plant**

**4.2 Final yield ( $Y_F$ ) and Reference Yield for Different Months of Year**

Final yield ( $Y_F$ ) is calculated by dividing the total AC energy produced by the PV system over a specified time (a day, a month, or a year) by the installed PV system's rated output power. The number of hours per day that the solar radiation would have to be at reference irradiance levels in order to contribute the same incident energy as was seen is represented by the reference yield. The results for final yield were quite similar to those of Gautam et al. [17], Bharathkumar and

Byregowda [18], and Kymakis et al. [19]. In Fig. 4, estimated values for both the final yield and the reference yield are shown as bars.

**4.3 Performance Ratio (PR) of Agrivoltaic System**

It represents all system losses experienced during the conversion from DC rating to AC output. Depending on the area, solar irradiance, and weather, PR typically ranges from 0.6 to 0.9. The experimental duration performance ratio was

determined in accordance with Table 2 and is depicted in Fig. 5. The performance ratio values found in this study and those from Kymakis et al. [19], Sharma and Chandel [20], and Bharathkumar and Byregowda [18] were very similar [21-23].

#### 4.4 Capacity Factor (CF) of SPV Power Plant for Different Months

Only the experimental duration was taken into account for the capacity factor (CF) computation. Therefore, the number of days in each month is substituted for the capacity factor 365 in the

formula. Table 3 lists the determined capacity factor values for each month [24,25].

#### 4.5 System Efficiency during Experimental Duration

Agrivoltaic construction has 48 panels in total, each measuring 1480 mm by 670 mm. A is therefore calculated as 47.60 m<sup>2</sup> for 48 panels. In accordance with Table 2, the monthly system efficiency for the study period is calculated and displayed in Fig. 6 [26,27]. The system efficiency numbers found in this study and those from Sharma and Chandel [20] agreed closely.




Fig. 4. Final yield and reference yield for different months





Fig. 5. Performance ratio for different months

**Table 3. Capacity factor for different months of study period**

Months	Capacity Factor (%)
January	18.08
February	17.11
March	19.81
April	20
May	21.53
June	20
July	12.92
August	10.76
September	11.25
October	12.49
November	13.33
December	15.07



**Fig. 6. System efficiency for different months**

## 5. CONCLUSION

The Department of Renewable Energy Engineering at JAU, Junagadh, built and installed an experimental SPV Power Plant design with a 7.2 kW capacity that covered an area of 153.88 m<sup>2</sup>. Total energy output during the experimental period was obtained as 10104.77 kWh and daily energy output was observed higher in May month. During monsoon season *i.e.* July, August, September and October energy generation is was found lower than other months. The overall performance ratio during the experimental period was observed as 80.83. The overall system efficiency during the experimental period was found as 12.07 %. This agrivoltaic technology is making a significant difference for future energy needs in India, where solar energy is available all year round.

## ACKNOWLEDGEMENTS

The Indian Council of Agricultural Research (ICAR) sponsored the project work through their Consortia Research Platform on Energy from Agriculture, which the authors are grateful for. The authors are grateful to Junagadh Agricultural University's College of Agricultural Engineering and Technology's Department of Renewable Energy Engineering for their excellent project guidance.

## COMPETING INTERESTS

Authors have declared that no competing interests exist.

## REFERENCES

1. Department of Economic and Social Affairs of United Nations, World population prospects; 2019.

- Available:<https://population.un.org/wpp/2019>. (Accessed 17 December 2021).
2. Amaducci S, Yin X, Colauzzi M. Agrivoltaic systems to optimise land use for electric energy production, *Appl. Energy*. 2018;220:545-561, Available:<https://doi.org/10.1016/j.apenergy.2018.03.081>.
  3. Kavlak G, Mc Nerney J, Trancik JE. Evaluating the causes of cost reduction in photovoltaic modules, *Energy Pol.* 2018;123:700-710, Available:<https://doi.org/10.1016/j.enpol.2018.08.015>.
  4. Victoria M, Haegel N, Peters IM, Sinton R, Jeager-Waldau A, Cannizzo C, del Breyer C, Stocks M, Blakers A, Kaizuka I, Komoto K, Smets A. Solar photovoltaics is ready to power a sustainable future, *Joule*. 2021;5:1041-1056, Available:<https://doi.org/10.1016/J.JOULE.2021.03.005>.
  5. IEA photovoltaic power systems programme, snapshot of global PV markets; 2021. Available:[https://iea-pvps.org/wp-content/uploads/2021/04/IEA\\_PVPS\\_Snapshot\\_2021-V3.pdf](https://iea-pvps.org/wp-content/uploads/2021/04/IEA_PVPS_Snapshot_2021-V3.pdf), 2021.
  6. Nonhebel S. Renewable energy and food supply: will there be enough land? *Renew. Sustain. Energy Rev.* 2005; 9: 191-201, Available:<https://doi.org/10.1016/j.rser.2004.02.003>.
  7. Weselek A, Ehmann A, Zikeli, S, Lewandowski I, Schindele S, Heogy P. Agrophotovoltaic systems: Applications, challenges, and opportunities. *A Review, Agron. Sustain. Dev.* 2019;39. Available:<https://doi.org/10.1007/S13593-019-0581-3/FIGURES/1>.
  8. Goetzberger A, Zastrow A. On the coexistence of solar-energy conversion and plant cultivation, *Int. J. Sol. Energy*. 1982;1:55-69. Available:<https://doi.org/10.1080/01425918208909875>
  9. Agostini A, Colauzzi M, Amaducci S. Innovative Agrivoltaic systems to produce sustainable energy: An economic and environmental assessment, *Appl. Energy*. 2021;281.
  10. Valle B, Simonneau T, Sourd F, Pechier P, Hamard P, Frisson T, Ryckewaert M, Christophe, A. Increasing the total productivity of a land by combining mobile photovoltaic panels and food crops, *Appl. Energy*. 2017;206: 1495-1507, Available:<https://doi.org/10.1016/j.apenergy.2017.09.113>
  11. Dinesh H, Pearce JM. The potential of Agrivoltaic systems, *Renew. Sustain. Energy Rev.* 2016;54:299-308. Available:<https://doi.org/10.1016/j.rser.2015.10.024>
  12. Dupraz C, Marrou H, Talbot G, Dufour L, Nogier A, Ferard Y. Combining solar photovoltaic panels and food crops for optimizing land use: Towards new Agrivoltaic schemes, *Renew. Energy*. 2011;36:2725-2732, Available:<https://doi.org/10.1016/j.renene.2011.03.005>.
  13. Irie N, Kawahara N, Esteves AM. Sector-wide social impact scoping of Agrivoltaic systems: a case study in Japan, *Renew. Energy*. 2019;139:1463-1476, Available:<https://doi.org/10.1016/j.renene.2019.02.048>.
  14. Leon A, Ishihara KN. Assessment of new functional units for Agrivoltaic systems, *J. Environ. Manag.* 2018;226:493-498, Available:<https://doi.org/10.1016/j.jenvman.2018.08.013>.
  15. Majumdar D, Pasqualetti MJ. Dual use of agricultural land: introducing 'Agrivoltaics' in phoenix metropolitan statistical area, USA, *Landsc. Urban Plann.* 2018;170:150-168. Available:<https://doi.org/10.1016/j.landurbplan.2017.10.011>.
  16. Marrou H, Dufour L, Wery J. How does a shelter of solar panels influence water flows in a soil-crop system? *Eur. J. Agron.* 2013;50:38-51. Available:<https://doi.org/10.1016/j.eja.2013.05.004>
  17. Gautam B, Ali Khan F, Singh A. Performance analysis of 5 MWp grid-connected solar PV power plant using IEC 61724. *International Research Journal of Engineering and Technology*. 2017;4(7): 2801-2805.
  18. Bharathkumar M, Byregowda HV. Performance evaluation of 5MW grid connected solar photovoltaic power plant established in Karnataka. *International Journal of Innovative Research in Science, Engineering and Technology*. 2014;3(6):13862-13868.
  19. Kaymakis E, Kalyakasis S, Papazoglou T. Performance analysis of a grid connected

- Photovoltaic Park on the island of Crete. Energy Conversion and Management. 2009;50:(3). DOI: 10.1016/j.enconman.2008.12.009
20. Sharma V, Chandel S. Performance analysis of a 190 kWp grid interactive solar photovoltaic power plant in India. Energy. 2013;55(C):476-485. DOI: 10.1016/j.energy.2013.03.075
  21. Dupraz C, Marrou H, Talbot G, Wery J, Roux S, Liagre F, Ferard Y, Nogier A. To mix or not to mix: Evidences for the unexpected high productivity of new complex Agrivoltaic and agroforestry systems. Renewable Energy. 2011;36(10):1-3.
  22. International Energy Agency -IEA, Electricity market report - July 2021. Available: <https://www.iea.org/reports/electricity-market-report-july-2021>. (Accessed 17 December 2021).
  23. International Energy Agency -IEA, Renewables; 2023. Paris. Available: <https://www.iea.org/reports/electricity-market-report-2023>.
  24. Kirmani, Sheeraz, Majid, Jamil and Iram, Akhtar. Effective low cost grid connected solar photovoltaic system to electrify the small scale industry/commercial building. International Journal of Renewable Energy Research. 2017;7(2):797-806. DOI: <https://doi.org/10.20508/ijrer.v7i2.5657.g7061>
  25. Marrou H, Guilioni L, Dufour L, Dupraz C, Wery J. Microclimate under Agrivoltaic systems: is crop growth rate affected in the partial shade of solar panels? Agric. For. Meteorol. 2013;177:117-132. Available: <https://doi.org/10.1016/j.agrforme.2013.04.012>.
  26. Marrou H, Wery J, Dufour L, Dupraz C. Productivity and radiation use efficiency of lettuces grown in the partial shade of photovoltaic panels. European Journal of Agronomy. 2013;44:54-66. Available: <https://doi.org/10.1016/j.eja.2012.08.003>.
  27. Pandya NN, Chaudhary ID. Growth of renewable/solar energy and government initiatives for roof-top system. International Journal for Technological Research in Engineering. 2017;4(10):2141- 2143.

© 2023 Patel et al.; This is an Open Access article distributed under the terms of the Creative Commons Attribution License (<http://creativecommons.org/licenses/by/4.0>), which permits unrestricted use, distribution, and reproduction in any medium, provided the original work is properly cited.

*Peer-review history:*

*The peer review history for this paper can be accessed here:*  
<https://www.sdiarticle5.com/review-history/103345>